

NON-CODE RELIEF SET/TEST FORM

DATE: 09/21/2010

REQUESTOR: Mark Ruschman 40/40.51.05.01

DEVICE(S): Unknown 3/8" MPT relief: 11/16" flats; knurled adjust; 3/4 jam nut;
.278 exit port, not threaded. O.A.L.: 1.702"

SERIAL # (IF ANY): N/A

DESCRIPTION OF WORK REQUEST: Set to 15 psi & test.

WORK PERFORMED: As above with testing & tags.

PARTS USED: none

PARTS RETURNED: none

TEST RESULTS:

	<u>Weeps@psi</u>	Relieves@psi	Resets@psi
Test#1	14.4	15.1	13.5
Test#2	14.3	15.1	13.5
Test#3	14.2	15.1	13.5

LABELED: paper label w/ weep/set/reset pressures across body seam.

DATE COMPLETED: 9/21/2010

COMPLETED BY: R. K. Barger